Wanner -

NJ Dept. of Community Affairs, Division of Fire Safety CH. 3, General Precautions Against Fire:

3074.1.1 Prohibited Open Burning

(that is offensive or objectionable due to smoke emissions, atmospheric conditions, or local circumstances make such fires hazardous)

Open Burn Exceptions:

- 1. Fires in approved containers with spark screen lid no less that 15FT from a structure
- Portable out door fireplaces shall be used in accordance with manufacture's instructions and not operated within 15FT of a structure or combustible material.
- The above acceptable burnings must be constantly attended until fire is extinguished. One portable fire extinguisher within a minimum 4-A rating or other approved on site extinguisher equipment.